

FIELD REPORT

Nitsch Project #:	12808	Date:	02/08/2020
Client:	Pine Hill Village, LLC	Time:	2:00 PM
Project:	Pine Hill Development	Location:	Harvard, Massachusetts
Weather:	30°F		
Present:	Gavin Graham – Nitsch Engineering		

The purpose of this site visit was to observe general site conditions, observe general construction activities, and erosion and sedimentation control measures. This site visit satisfies the weekly site visit requirement by Nitsch Engineering.

Nitsch Engineering notes the overall good condition of the erosion control barriers around the perimeter of the site. There were no breaks in the fencing. The majority of the site was covered in a sheet of ice.











Past Recommended Items to be Completed:

1. Completed – Contractor to install additional straw wattle on downstream section of intermittent stream; and
2. Completed – Stabilized construction entrance needs to be replenished with fresh gravel.

New Recommended Items to be Completed:

1. n/a

Ongoing Recommendations:

1. Contractor to maintain stabilized construction entrance;
2. Contractor to maintain erosion control barriers; and
3. Developer must provide all parties with weekly updates including construction sequences and a detailed schedule, per conversation with the Town of Harvard. This includes contractors who are working on the site, the Town of Harvard, and representatives of Nitsch Engineering.

If there are any questions, please do not hesitate to contact:

Gavin Graham

Gavin Graham 857-206-8690
Project Designer ggraham@nitscheng.com
GNG